Wallstone and Wedgestone

DESCRIPTION

Wallstone and Wedgestone wall can be used separately or in combination for greater flexibility.

Suitable for gravity or grid, vertical or setback, straight or curved walls. All Wallstone and Wedgestone wall component units come pre-split. End grooves on Wallstone standard units maintain interlock between courses, even when placed vertically. Two thirds of standard units are also double rock-faced.

Wedgestone wall units are 100% double rock-faced and reversible for inside and outside curves. Units create a 600 mm - 2 in. outside radius without cutting.

TIP

4 Wedgestone wall units are required for a rounded 90° corner, 16 pcs for a full circle.


Patterned Wallstone walls can be stacked vertically up to 6 courses high (7 courses if using a Wallstone double unit in the base) or up to 8 courses if 50% of units have at least a one groove setback and a Wallstone double unit is used in the base course.

WALLSTONE UNITS

STANDARD UNIT

200 mm 3 15/16 in. 200 mm 7 7/8 in.

12 IN. CAPPING UNIT




WEDGESTONE UNITS


STANDARD UNIT



CAPPING UNIT



CORNER/COLUMN UNIT




PATTERNS

PATTERN 1

Place Wallstone standard units vertically and horizontally to create interesting patterns within the wall.

PATTERN 2 Add an additional dimension to your wall


Add an additional dimension to your wall by including Wedgestone wall units in your pattern (shaded).




Consider recessing blocks to add further distinction. Except for the coping course, it is not recommended to set units forward beyond the front of the base course.

CROSS-SECTION -SETBACK GRAVITY WALL


2 FOOT WALL HEIGHT



4 FOOT WALL HEIGHT



6 FOOT WALL HEIGHT



NOTES


- 01 Sample designs based on 2.4 kPa (50 psf) pedestrian surcharge. Use as preliminary design only when actual soil and surcharge conditions are conservatively represented by the standard engineering. In all cases, designs should be reviewed by a geotechnical engineer to ensure applicability to site.
- 02 Designs consider free draining sand and gravel backfill material compacted to 95% SPMDD to a minimum depth of 375 mm 15 in. behind the wall or to full extent of geogrid reinforcement, whichever is greater. Backfill materials to have less than 8% passing through the # 200 sieve.
- 03 Designs consider 19 mm 0 to 3/4 in. well graded, crushed angular granular materials for a minimum depth of 200 mm 8 in. under the wall compacted to 98% SPMDD. Material to have less than 8% passing through the # 200 sieve.
- 04 Designs consider minimum bearing capacity in subgrade soil below wall of 150 kPa (3000 psf).
- 05 Different batter configurations, surcharge conditions or wall heights require different design configurations.
- 06 No provision has been made for overall global stability of the designs.
- 07 Minimum 100 mm 4 in. of product must be buried in all situations. Design may require more depending on soil conditions or toe slope.
- $\ensuremath{\mathsf{08}}$ $\ensuremath{\mathsf{Grid}}$ lengths are measured from front face of wall.
- 09 Geogrid used in designs is Miragrid 2XT or 3XT.
- 10 Designs for wall heights, batters and surcharges not represented on these pages can be attained from Permacon.
- 11 Refer to standard engineering drawings for further details.
- 12 Total wall height for Wallstone wall does not include coping unit.
- 13 Sample designs are not designed for handrail, guard or fence loading. In these cases, design modifications will be required.
- 14 Poor soil conditions and excessive moisture will require drainage and design modifications.

CROSS-SECTION -SETBACK VERTICAL WALL


2 FOOT WALL HEIGHT

Total wall height: 0.6 m - 2 ft. 0.65 m - 2.1 ft.

4 FOOT WALL HEIGHT




6 FOOT WALL HEIGHT




NOTES


- 01 Sample designs based on 2.4 kPa (50 psf) pedestrian surcharge. Use as preliminary design only when actual soil and surcharge conditions are conservatively represented by the standard engineering. In all cases, designs should be reviewed by a geotechnical engineer to ensure applicability to site.
- 02 Designs consider free draining sand and gravel backfill material compacted to 95% SPMDD to a minimum depth of 375 mm 15 in. behind the wall or to full extent of geogrid reinforcement, whichever is greater. Backfill materials to have less than 8% passing through the # 200 sieve.
- 03 Designs consider 19 mm 0 to 3/4 in. well graded, crushed angular granular materials for a minimum depth of 200 mm 8 in. under the wall compacted to 98% SPMDD. Material to have less than 8% passing through the # 200 sieve.
- 04 Designs consider minimum bearing capacity in subgrade soil below wall of 150 kPa (3000 psf).
- 05 Different batter configurations, surcharge conditions or wall heights require different design configurations.
- 06 No provision has been made for overall global stability of the designs.
- 07 Minimum 100 mm 4 in. of product must be buried in all situations. Design may require more depending on soil conditions or toe slope.
- 08 Grid lengths are measured from front face of wall.
- 09 Geogrid used in designs is Miragrid 2XT or 3XT.
- 10 Designs for wall heights, batters and surcharges not represented on these pages can be attained from Permacon.
- 11 Refer to standard engineering drawings for further details.
- 12 Total wall height for Wallstone wall does not include coping unit.
- 13 Sample designs are not designed for handrail, guard or fence loading. In these cases, design modifications will be required.
- 14 Poor soil conditions and excessive moisture will require drainage and design modifications.


CORNER - SINGLE DEPTH






CORNER - MULTI DEPTH






STEPS

A double unit in the base of the bottom of the riser adds





TO CALCULATE PRODUCT REQUIREMENTS:

Double units = step width x 1 Standard units = step width x 2 x # of risers + step width x 1 Coping units = step width \div by coping width x # of risers